

REGIONAL WATER TESTING LAB, MOGA

Near BSNL exchange, water works, Moga (Ajitwal)
rwtlmoga@gmail.com

TEST REPORT

Name & Address of Customer : SACRED HEART CONVENT SCHOOL, Moga Barnala Road, Dhurkot kalan	Customer Reference No.	No : Ref No. SHCS/GEN-25-26/1-02 Dated : 28/04/2025
	Sample Submitted by	Jagjodh Singh
	Date of Sample Receipt	28/04/2025
	Analysis Starting Date	28/04/2025
	Analysis completion Date	30/04/2025
Discipline : Bacteriological Testing		
Group: Water		
ULR No.:	Sample Type :	Water
Test Report No.: RWTLMOG/2526/00045	Date of Issue :	03/05/2025
Registration no.: RWTLMOG/REG2526/00161	Condition of Sample :	Unsealed
Collection Point: Private Submersible	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source: Not Mentioned(Not Mentioned)	Location/Depth :	School Motor Water (Sacred Heart convent School, Dhurkot Kalan) / NA
Village : Dhurkot Kalan	Habitation :	Dhurkot Kalan
Block: Moga-I	District :	Moga
Latitude : Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	Total Coliform(TC)	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method
2	E-Coli	ND	Shall not be detectable in any 100 ml sample	No relaxation	MPN/100 ml.	IS-1622 MPN Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By



Ashish Kumar
Sr. Chemist
Authorized Signatory
For, Regional Water Testing Lab
Moga

----- End of the Test Report -----